



LONDON FIRE BRIGADE

FIRE SAFETY GUIDANCE NOTE

Hand Held Portable Firefighting Equipment

Number:

GN08

The London Fire Commissioner (the Commissioner) is the fire and rescue authority for London. The Commissioner is responsible for enforcing the Regulatory Reform (Fire Safety) Order 2005 (The Order) in London.

This Guidance Note provides advice on types and siting of extinguishers for both commercial and residential properties.

This Note is one of a series produced by the Commissioner to provide advice on various aspects of fire safety. If you require any further guidance on the advice given or require advice on another topic please contact your local Fire and Community Safety Centre or visit our web site at

<http://www.london-fire.gov.uk>

CONTENTS:

1	INTRODUCTION	2
2	OTHER AUTHORITIES YOU MAY NEED TO CONSULT	2
3	GENERAL PRINCIPLES	2
4	COLOUR OF FIRE EXTINGUISHERS	3
5	CLASSIFICATION AND RATING OF EXTINGUISHERS	4
6	LOCATION	4
7	MAINTENANCE AND DISPOSAL	4
8	TRAINING	4
9	BIBLIOGRAPHY	5

1 INTRODUCTION

- 1.1 To help prevent small fires growing into larger fires, suitable fire fighting equipment should be readily available at all times. On most occasions the equipment available will be of the hand-held portable type, but in some circumstances fixed or automatic fire fighting equipment may be provided.
- 1.2 In small premises, having one or two portable extinguishers of the appropriate type readily available for use may be all that is necessary. In larger, more complex premises, more portable extinguishers may be required and they should be sited in suitable locations, such as on the escape routes at each floor level. It may also be necessary to indicate the location of extinguishers by suitable signs. The Fire Risk Assessment (FRA) for the premises will detail this requirement. See 5.2.

2 OTHER AUTHORITIES YOU MAY NEED TO CONSULT

- 2.1 The Commissioner enforces fire safety legislation in many areas, but not all. Therefore, before providing fire-fighting equipment you are advised to consult the relevant enforcing authority. Depending upon where the equipment is to be provided the other authorities involved may include:
- Health and Safety Executive e.g. construction sites.
 - Crown Premises Inspection Group (CPIG) e.g. prisons.
 - MOD fire service e.g. army base
 - Local authority (contact the local borough council to find out which department may be involved)
- 2.2 Insurance companies may also wish to augment the number and type of extinguishers covering a specific risk as a condition to issuing an insurance policy.

3 GENERAL PRINCIPLES

- 3.1 Portable fire fighting equipment should be allocated appropriate to the perceived fire risk. This should be classified by the extinguisher rating, and not the extinguisher size, weight or content in litres. See 5.1
- 3.2 Different types of fire risk require the use of specific extinguishing agents. British Standard BS EN 2 classifies these risks according to material involved. Appropriate extinguishing media have been indicated below:

CLASS OF MATERIALS INVOLVED	EXTINGUISHING MEDIA
CLASS A: Fires involving solid materials usually of an organic nature in which combustion normally takes place with the formation of glowing embers, e.g. wood, paper or textiles.	Extinguishers with an 'A' rating: e.g. 13A Types include: Water extinguisher, Foam Extinguisher, Dry Powder extinguisher (size according to risk).
CLASS B: Fires involving liquids or liquefiable solids, e.g. petrol, diesel or oils.	Extinguishers with a 'B' rating: e.g. 34B Types include: Foam extinguisher, CO ² extinguisher, Dry powder extinguisher (size according to risk).
CLASS C: Fires involving gases	Foam extinguisher (according to risk) Seek specialist advice.
CLASS D: Fires involving metals	Special powder extinguishers (size and type according to risk), dry sand (quantity according to risk). Seek specialist advice.
CLASS F: Fires in cooking appliances that involves vegetable or animal fats.	Extinguishers with an 'F' rating: e.g. 15F Types include: Foam extinguisher, CO ² extinguisher, Dry powder extinguisher (size according to risk).

- 3.3 Fire extinguishers should conform to BS EN 3 and be maintained as outlined in BS 5306: Part 3. Schemes for ensuring the conformity with these Standards have been produced by the British Standards Institution and adopted by British Approvals for Fire Equipment (BAFE) and conforming equipment and services are recognised by that organisation's mark of approval.
- 3.4 A recent innovation is the 20 year life cycle extinguisher that needs to be refilled/ refurbished after 10 years by the manufacturer. These extinguishers enable a business or organisation to carry out their own maintenance with a simple visual inspection that is required at least annually. Depending on the type and location of the extinguisher, it may be appropriate to perform a visual inspection at shorter intervals (e.g. monthly). These extinguishers are either dry powder or foam within a Kevlar lined container and covered with a composite outer casing. Due to the 10 year operational corrosion guarantee they do not require a traditional service contract. These extinguisher types meet the requirements of the Order and are therefore acceptable to the Commissioner. The extinguishers meet the di-electric test as detailed in British Standard 3 – 7 (BS EN 3- 7) and have received various third party approvals. They are suitable for a number of locations within a premises and come in various sizes. The FRA will provide detailed information with regard to their location and placement, see paragraph 5.2.

Fire blankets

- 3.5 Fire blankets primarily intended for extinguishing cooking oil fires are described in BS EN 1869. These can also be used for fires involving personal clothing.
- 3.6 Heavy-duty fire blankets and heat protective blankets primarily for industrial use are described in BS 7944.

4 COLOUR OF FIRE EXTINGUISHERS

- 4.1 The body colour of fire extinguishers is Signal Red, irrespective of the extinguishing media they contain. When existing extinguishers are replaced there will be an interim period where both the new and old schemes of colour indication may be found side by side in the same premises. Existing extinguishers do not have to be replaced just to conform to the new colour scheme. However, they must be "fit for purpose", serviced and tested in accordance with the most up to date specification.
- 4.2 Certain companies have extinguishers that co-ordinate to their specific 'Brand' and therefore, silver or grey extinguisher bodies are still utilised. These may still have the 5% surface area in colour as detailed in 4.3 below.
- 4.3 In the UK a colour zone of up to a maximum of 5% of the surface area of the extinguisher body may be used to identify the extinguishing agent. If used the colours will indicate: (Vaporising Liquid Extinguishers were coloured green and may still be found in certain applications).

<u>EXTINGUISHING AGENT</u>	<u>COLOUR</u>
Water	RED
Foam	PALE CREAM
Powder (all types)	BLUE
Carbon Dioxide (CO2)	BLACK
Wet Chemical	CANARY YELLOW

5 CLASSIFICATION AND RATING OF EXTINGUISHERS

- 5.1 The scheme for the classification and rating of class A & B extinguishers is detailed in BS EN 3-7. BS EN 3-7 specifies the characteristics, performance requirements and test methods for portable fire extinguishers. On successful completion of the tests, a fire test rating is awarded to the extinguisher and this is indicated on the instruction label (e.g. 13A, 34B, 15F).
- 5.2 The type, quantity and distribution of extinguishers throughout the premises should be based on the risks identified in the FRA. The performance rating of the extinguishers is an important factor in this Assessment, a 13A extinguisher need not be the heavy 9 litre water extinguisher found in many premises. A smaller version that still meets the 13A criteria is just as effective. A 2.5 kilogram Carbon Dioxide (CO²) extinguisher is rated as a 34B. BS 5306-8 is a code of practice that details the recommendations concerning the selection and installation of portable fire extinguishers.

6 LOCATION

- 6.1 Fire extinguishers should normally be located in conspicuous positions on escape routes, preferably near exit doors. Wherever possible, fire-fighting equipment should be grouped to form fire points. If extinguishers are placed in positions hidden from direct view, the Health & Safety (Safety Signs & Signals) Regulations 1996 require that their location be indicated by signs and, where appropriate, directional arrows.
- 6.2 Fire extinguishers can be either hung on suitable wall brackets or placed in purpose made stands. These stands often have the details of the specific extinguishers printed on the back of the stand. The stands are useful as if it is empty you are aware that an extinguisher is missing and needs to be replaced.

7 MAINTENANCE AND DISPOSAL

- 7.1 Regular inspection by the user should ensure that:
- (a) Each extinguisher is located in its designated place.
 - (b) Operating instructions are clean and legible.
 - (c) Each extinguisher has not been operated and not obviously damaged.
 - (d) Any pressure gauge or indicator is within operational and safety limits.
 - (e) The seals and tamper indicators are not broken or missing.
- 7.2 Basic servicing should be carried out annually by a competent person. However, see paragraphs 3.4 and 8.2
- 7.3 Extended servicing, including discharging and recharging should be carried out as detailed in BS 5306-3. However, see paragraph 3.4 above.
- 7.4 Maintenance tests of all extinguisher types should be recorded.
- 7.5 The link detailed, can assist those who need to dispose of fire extinguishers.
<http://www.fireprotectionrecycling.co.uk/>

8 TRAINING

- 8.1 All staff should be familiar with the location and basic operating procedures for the equipment provided, in case they need to use it. If your fire strategy means that certain people, e.g. fire marshals, will be expected to take a more active role, then they should be provided with more comprehensive training.
- 8.2 For staff who are to undertake in house inspections of the 20 year life cycle extinguishers, it is important that they have been appropriately trained and receive the correct equipment to be able to carry out this task.

9 BIBLIOGRAPHY

9.1 Detailed guidance on the various standards listed in the guidance note may be obtained from the following bibliography.

AVAILABLE FROM	TITLE
British Standards Institution (Sales) 389 Chiswick High Road London W4 4AL Telephone: 020 7996 9000 Fax: 020 7996 7001 E-mail: cservices@bsi-global.com Web: www.bsi-global.com	BS 5306-8: Selection and Installation of portable fire extinguishers – Code of practice BS 5306-3: Code of practice for the inspection and maintenance of portable fire extinguishers. BS EN3 : Parts 6 - 9 Portable Fire Extinguishers BS EN2: Classification of fires BS 7863: Colour coding to indicate the extinguishing media contained within portable fire extinguishers BS EN 1869: Fire Blankets BS 7944: Type 1 Heavy duty fire blankets and Type 2 Heavy duty heat protective blankets. BS 9999: Code of practice for fire safety in the design, management and use of buildings BS 9991: Fire safety in the design, management and use of residential buildings. Code of practice BS 6165: Specification for Small Disposable Fire Extinguishers of the Aerosol Type BS 6643: Recharging Fire Extinguishers

<p>The Stationery Office (Mail, Telephone, Fax & Internet Orders)</p> <p>TSO Orders/Post Cash Dept PO Box 29 Norwich NR3 1GN</p> <p>Telephone: 0870 600 5522 Fax orders: 0870 600 5533 Web: www.tso.co.uk</p>	<p>Fire safety in offices and shops ISBN-13: 978 1 85112 815 0</p> <p>Fire safety in factories and warehouses ISBN-13: 9778 1 85112 816 7</p> <p>Fire safety in premises providing sleeping accommodation ISBN-13: 978 1 85112 818 1</p> <p>Fire safety in residential care premises ISBN-13:978 1 85112 818 1</p> <p>Fire safety in educational premises ISBN-13: 978 1 85112 819 8</p> <p>Fire safety in small and medium places of assembly ISBN-13: 978 1 85112 820 4</p> <p>Fire safety in large places of assembly ISBN-13: 978 1 85112 821 1</p> <p>Fire safety in theatres and cinemas ISBN-13: 978 1 85112 822 8</p> <p>Fire safety at outdoor events ISBN-13: 978 1 85112 823 5</p> <p>Fire safety in healthcare premises ISBN-13: 978 1 85112 824 2</p> <p>Fire safety in the transport network ISBN-13: 978 1 85112 825 9</p> <p>Fire Safety Risk Assessment - Means of Escape for Disabled People ISBN: 978 1 85112 873 7</p>
<p>Communities & Local Government www.communities.gov.uk</p>	<p>A short guide to making your premises safe from fire Product code: 05 FRSD 03546</p>
<p>Health & Safety Executive</p> <p>Order a Publication: 01787 881 165 Website: www.hsebooks.com</p>	<p>Health & Safety (Safety Signs & Signals) Regulations 1996</p>

The above publications are current at the time of preparation of this Guidance Note, (see date at foot of last page).

The "Fire Safety" guides listed above may also be downloaded free of charge from the Fire Safety Law Section of the CLG website at: www.gov.uk/workplace-fire-safety-your-responsibilities